

April Antonelli
District Economic Development Engineer
MassDOT Highway Division|District 4
519 Appleton Street|Arlington, MA 02476

From: Antonelli, April S. (DOT) <April.S.Antonelli@dot.state.ma.us>
Sent: Wednesday, December 20, 2023 1:56 PM
To: billcamuso@gmail.com; jbernardino@cmgenv.com
Cc: Tirone, Charles <ctirone@ci.reading.ma.us>; Romano, Ralph R. (DOT) <Ralph.Romano@dot.state.ma.us>
Subject: Reading - 87 Walkers Brook Drive

CAUTION: This email originated from outside your organization. Exercise caution when opening attachments or clicking links, especially from unknown senders.

Bill/James,

The Town of Reading contacted MassDOT District 4 regarding the NOI submission related to this site. The site access and storm drain connections was approved in 2007 by MassDOT District 4 under state highway access permit 4-2007-0109, see attached. Any new improvements within the limit of state highway/property will require a new access permit submission by the property owner. District 4 will review the application and provide any recommendation and or comments. The new application should provide all local approvals and conditions.

Currently, there is an unpermitted illicit discharge point on MassDOT layout (LO), the surface discharge (illicit discharge) drains into a Zone A wetland and Riverfront which violates Local Wetland Protection Act. See attached photograph. This break in the curb needs to be removed immediately, MassDOT D4 is hoping that you as the property owner will remove and provide a site surface drainage solution, since it was installed under the issued 2007 access permit.

Link to 87 Walkers Brook Drive

https://www.google.com/maps/@42.5179424,-71.0920953,3a,75y,316.29h,72.22t/data=!3m6!1e1!3m4!1ss_xGo2xpwcoyiWrypyORPA!2e0!7!16384!8i8192?entry=ttu

Screenshot of unauthorized illicit discharge



Thank you for your response to this email. Copied on this email is Reading Conservation Administrator, Chuck Tirone.

April

April Antonelli
District Economic Development Engineer
MassDOT Highway Division|District 4
519 Appleton Street|Arlington, MA 02476