

Scott Harris
550 West St.
Reading, MA 01867

Drywell Maintenance Plan

- 1) Remove leaves and tree debris from roof gutters
- 2) Remove debris (grass clippings, branches, pine needles, etc.) from opening of the dry well
- 3) Repair any damage to gutters/downspouts from winter snow or ice
- 4) Check for standing water
- 5) Inspect drywells after every major storm in the first few months after construction to ensure proper stabilization and function. Inspect annually after that.